

ELECTRICAL INSTALLATION CONDITION REPORT

(Requirements for Electrical Installations - BS 7671)

Report No: **161123**

SECTION A: DETAILS OF THE PERSON ORDERING THE WORK

Name:

Address:

Postcode:

SECTION B: REASON FOR PRODUCING THIS REPORT

ELECTRIC SAFETY CERTIFICATE

Date(s) on which the inspection and testing was carried out: **16-11-23**

SECTION C: DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: **HART UNITED REFORMED CHURCH**

Address: **MAJOR DRIVE**

HART

(USE BLOCK LETTERS)

Postcode:

Description of premises:
Residential ☐ Commercial ☒ Industrial ☐ Other (Briefly describe) ☐

Estimated age of wiring system years

Evidence of additions/alterations? Yes ☐ No ☐ Not apparent ☐

Installation records available? (Regulation 651.1) Yes ☐ No ☒

If yes, estimate age years
Date of last inspection (date)

SECTION D: EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of installation covered by this report **DB 4 CHURCH AREA FRONT ENTRANCE**

Agreed limitations including the reasons (see Regulation 653.2)

Agreed with Operational limitations including the reasons (see page no)

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 as amended to **2013**
It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SECTION E: SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety) **GOOD THROUGHOUT**

Overall assessment of the installation in terms of its suitability for continued use **UNSATISFACTORY/UNSAFE** (Delete as appropriate)

*An unsatisfactory assessment indicates that a dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

SECTION F: RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classed as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (Code FI). Observations classed as 'Improvement recommended' (code C3) should be given due consideration.

Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by **15/11/25** (date) for the following reason(s)

SECTION G: DECLARATION

I/We being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures shown adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information on this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in Section D of this report.

Inspected and tested by: (USE BLOCK LETTERS)

Name: **HOWARD ROSE**

Signature: **Howard Rose**

For/on behalf of: **LEVER FINE SECURITY**

Position: **ELECTRICIAN**

Address: **UNIT HM 25**

Postcode: **HM3 63U**

Date: **16-11-23**

Report authorised by: (USE BLOCK LETTERS)

Name:

Signature:

For/on behalf of:

Position:

Address:

Postcode:

Date:

SECTION H: SCHEDULES

Inspection Schedule(s) and Schedule(s) of Circuit Details and Test Results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

Earthing arrangements	Number and Type of Live Conductors	Nature of Supply Parameters	Supply Protective Device	Other Sources of Supply
TN-C <input type="checkbox"/> TN-S <input type="checkbox"/> TN-C-S <input checked="" type="checkbox"/> TT <input type="checkbox"/> IT <input type="checkbox"/>	AC <input checked="" type="checkbox"/> 1-phase, 2-wire <input checked="" type="checkbox"/> 2-phase, 3-wire <input type="checkbox"/> 3-phase, 3-wire <input type="checkbox"/> 3-phase, 4-wire <input type="checkbox"/> DC <input type="checkbox"/> 2-wire <input type="checkbox"/> 3-wire <input type="checkbox"/> Other <input type="checkbox"/>	Nominal voltage, $U / U_0^{(1)}$ <u>230 V</u> Nominal frequency, $f^{(1)}$ <u>50</u> Hz Prospective fault current, $I_{pf}^{(2)}$ <u>1.13</u> kA External earth fault loop impedance, $Z_e^{(2)}$ <u>0.11</u> Ω <small>Note: (1) By enquiry (2) by enquiry or by measurement</small>	BS (EN) <u>60898</u> Type <u>B</u> Rated current <u>80</u> A	Details of supply source: <u>/</u> Power rating of supply source <u>/</u> kW Prospective fault current, I_{pf} <u>/</u> kA Electrode resistance to earth <u>/</u> Ω <small>(See further details on attached schedule)</small>

SECTION J: PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing	Maximum Demand	Details of Installation Earth Electrode (where applicable)
Distributor's facility <input checked="" type="checkbox"/> Installation earth electrode <input type="checkbox"/>	Maximum demand (load) <u>75</u> kVA <small>(Delete as appropriate)</small>	Location of earth electrode <u>/</u> Type of earth electrode (e.g. rod(s), tape etc.) <u>/</u> Electrode resistance to Earth <u>/</u> Ω

MAIN PROTECTIVE CONDUCTORS

Earthing conductor	Main protective bonding conductors	Main protective bonding conductors connected to:
Material <u>COPPER</u> csa <u>16</u> mm ² Connection / continuity verified <input checked="" type="checkbox"/>	Material <u>COPPER</u> csa <u>10</u> mm ² Connection / continuity verified <input checked="" type="checkbox"/>	Metallic water installation pipes <input checked="" type="checkbox"/> Metallic gas installation pipes <input checked="" type="checkbox"/> Metallic oil installation pipes <input type="checkbox"/> Structural steel <input type="checkbox"/> Lightning protection <input type="checkbox"/> Other: <u>/</u>

MAIN SWITCH / SWITCH-FUSE / CIRCUIT-BREAKER / RCD

Location:	Current rating	RCD Type
BS (EN) <u>60439-3</u> No of poles <u>TWO</u>	Fuse / device rating or setting <u>100</u> A Voltage rating <u>230/400 V</u>	Rated residual operating current ($I_{\Delta n}$) <u>/</u> mA Rated time delay <u>/</u> ms Measured operating time <u>/</u> ms

SECTION K: OBSERVATION(S)

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results, and subject to the limitations specified at the EXTENT AND LIMITATIONS OF INSPECTION AND TESTING section.

No remedial action is required ☒ The following observations are made ☐ (see below)

OBSERVATION(S): Include schedule reference as appropriate

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action. C1 - Danger present. Risk of injury. Immediate remedial action required C2 - Potential dangerous - urgent remedial action required C3 - Improvement recommended FI - Further investigation required without delay
--

DISTRIBUTION BOARD DETAILS

DB reference: DB4Location: CHURCH ENTRANCE Supplied from: DB1

Distribution circuit OCPD: BS(EN) _____ Type: _____ Rating/Setting: _____

SPD Details Type(s)*: T1 ☐ T2 ☐ T3† ☐ N/A ☒

NOTES

* Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both type boxes.
 † Where a T3 SPD is installed to protect sensitive equipment, enter its details in the 'Remarks' column of this schedule. (See Section 534 of BS 7671 as amended)
 § Where the maximum permitted earth fault loop impedance value stated in column 12 is taken from a source other than Chapter 41 of BS 7671 (as amended), state the source of the data for the circuit in the 'Remarks' column.

TEST RESULT DETAILS

Circuit number		Circuit description	Type of wiring	Conductor details		Overcurrent protective device					RCD device details		
Number & size	Live (mm ²)			cpc (mm ²)	BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Maximum permitted Z _s (Ω)§	BS (EN)	Type	I _{Δn} (mA)	Rating (A)
1	LADIES HAND DRYER	A	1	2.5	1.5	60898	B	16	6	1.71			
2	SOCKETS BEHIND PODIUM	A	1	2.5	1.5	60898	B	16	6	1.71			
3	KITCHEN WATER HEATER	A	1	2.5	1.5	60898	B	16	6	1.71			
4	MENS HAND DRYER	A	1	2.5	1.5	60898	B	20	6	1.71			
5	PANTRY LIGHTING	A	3	1.5	1.0	60898	B	6	6	1.71			
6	WATER & FAN SIDE LIGHTS	A	6	1.5	1.0	60898	B	6	6	1.71			
7	MIDDLE & SPOT LIGHTS	A	8	1.5	1.0	60898	B	6	6	1.71			
8	STAGE, SIDE ROOMS & PICTURE LIGHTS	A	6	1.5	1.0	60898	B	6	6	1.71			
9	ENTRANCE & SIDE STAIRS LIGHTS	A	6	1.5	1.0	60898	B	6	6	1.71			
10	HALL & KITCHEN SICKS	A	4	2.5	1.5	60898	B	20	6	1.71			
14	HALL SOCKETS	A	2	2.5	1.5	60898	B	20	6	1.71			
15	ENTRANCE & R.H STAIRS SICKS	A	2	2.5	1.5	60898	B	20	6	1.71			
16	TOP Floor SICKS & BEHIND ENTRANCE	A	1	2.5	1.5	60898	B	32	6	1.71			

CODES FOR TYPES OF WIRING

A	B	C	D	E	F	G	H	O
Thermoplastic insulated/ sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic SWA cables	Thermosetting SWA cables	Mineral insulated cables	Other - please state

DB reference: DB 4 Zdb 0.11 Ω 1φ I_{pf} 1.13 kA
Confirmed: Correct polarity ☒ Phase sequence ☐ 3φ I_{pf} kA
SPD: Operational status confirmed ☐ N/A ☒ Note: Not all SPDs have visible functionality indication.

Tested by (Capital): HOWARD ROSE
Signature: Howard Rose Date: 16-11-23.

TEST RESULT DETAILS

Circuit number	Continuity (Ω)		Insulation resistance (MΩ)				Zs (Ω)	RCD	AFDD	Remarks Include details of circuits and/or installed equipment vulnerable to damage when testing (Continue on a separate sheet if necessary)										
	Ring final circuit	(R ₁ + R ₂) or R ₂ <small>(Complete one column)</small>	Single-phase		Three-phase															
			Test voltage (V)	Live - Live	Live - Earth	L ₁ + L ₂ + L ₃ + N to E					L ₁ + L ₂ + L ₃ to N	L ₁ + L ₂ to L ₃	L ₁ to L ₂							
	r ₁ (line)	r _n (neutral)	r ₂ (cpc)	(R ₁ + R ₂)	R ₂															
1	—	—	—	—	.09	500	—	7200	—		—	—	—	✓						
2	—	—	—	—	.04	500	—	7200	—	—	—	—	✓							
3	—	—	—	—	.18	500	—	7200	—	—	—	—	✓							
4	—	—	—	—	.22	500	—	7200	—	—	—	—	✓							
5	—	—	—	—	.08	500	—	7200	—	—	—	—	✓							
6	—	—	—	—	.18	500	—	7200	—	—	—	—	✓							
7	—	—	—	—	.14	500	—	7200	—	—	—	—	✓							
8	—	—	—	—	.09	500	—	7200	—	—	—	—	✓							
9	—	—	—	—	.28	500	—	7200	—	—	—	—	✓							
13	.11	.11	.23	.34	—	500	0	7200	—	—	—	—	✓							
14	.12	.12	.25	.39	—	500	0	7200	—	—	—	—	✓							
15	—	—	—	—	.09	500	—	7200	—	—	—	—	✓							
16	—	—	—	—	.23	500	—	7200	—	—	—	—	✓							

DETAILS OF TEST INSTRUMENTS USED (SERIAL AND/OR ASSET NUMBERS)

Multi-function: Continuity: BD2013270 Insulation resistance: BD2013270

Earth fault loop impedance: BS201375 RCD: BS2016744 Earth electrode resistance:

NOTES

Where this schedule is issued with an Electrical Installation Condition Report, and incorrect polarity is identified, an X should be entered.

** RCD effectiveness is verified using an alternating current test at rated residual operating current (I_{Δn}).

The persons responsible for the periodic inspection should include the relevant items in relation to the electrical installation, the inspection schedule can be reduced or expanded depending on the requirements for the installation.

Possible outcomes:

- Acceptable condition
 - Unacceptable condition
 - Improvement recommended
 - Further investigation
- ✓
 C1 or C2
 C3
 FI
- Not verified
 - Limitation
 - Not applicable
- N/V
 LIM
 N/A

Item No.	Description	Outcome	Item No.	Description	Outcome
1.0	INTAKE EQUIPMENT (VISUAL INSPECTION ONLY) An outcome against an item in this section other than access to live parts, should not be used to determine the overall outcome.		4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)	
1.1	Distributor supplier intake equipment <ul style="list-style-type: none"> • Service cable • Service head • Earthing arrangement • Meter tails • Metering equipment • Isolator (where present) NOTE 1: Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority. NOTE 2: For this section only, where inadequacies are found, an 'X' should be put against the appropriate item and the comment made in Section K	✓	4.1	Adequacy of working space accessibility to consumer unit / distribution board (132.12; 513.1)	✓
1.2	Consumer's isolator (where present)	Y / NA	4.2	Security of fixing (134.1.1)	✓
1.3	Consumer's meter tails		4.3	Condition of enclosure(s) in terms of IP rating etc. (416.2)	✓
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICRO GENERATORS (551.6; 551.7)	✓	4.4	Condition of enclosure(s) in terms of fire rating etc. (421.1.201; 526.5)	✓
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)		4.5	Enclosure not damaged / deteriorated so as to impair safety (651.2)	✓
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	N/A	4.6	Presence of a main linked switch (as required by 462.1.201)	✓
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)		4.7	Operation of main switch (functional check) (643.10)	✓
3.3	Provision of earthing / bonding labels at all appropriate locations (514.13.1)		4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (643.10)	✓
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)		4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
3.5	Access ability and condition of earthing conductor at MET (543.3.2)		4.10	Presence of RCD six-monthly test notice, where required (514.12.2)	✓
3.6	Confirmation of main protective bonding conductor sizes (544.1)		4.11	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)	N/A
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)		4.12	Presence of other required labelling (please specify) (Section 514)	N/A
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)	✓	4.13	Compatibility of protective devices, bases and other components; correct type and rating no signs of unacceptable thermal damage, arcing or overheating (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	✓
			4.14	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.3)	✓
			4.15	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.5; 522.8.11)	✓
			4.16	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1)	✓
			4.17	RCD(s) provided for fault protection – includes RCBOs (411.4.204; 411.5.2; 531.2)	✓
			4.18	RCD(s) provided for additional protection requirements – includes RCBOs (411.3.3; 415.1)	✓
			4.19	Confirmation of indication that SPD is functional (651.4)	✓
			4.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
			4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A

Item No.	Description	Outcome
4.22	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
5.0	FINAL CIRCUITS	
5.1	Identification of conductors (514.3.1)	✓
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
5.3	Condition of insulation of live parts (416.1)	✓
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1) • To include the integrity of conduit and trunking systems (metallic and plastic)	✓
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
5.9	Wiring systems appropriate for the type and nature of installation and external influences (Section 522)	✓
5.10	Concealed cables installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	✓
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)	✓
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA: • for all socket-outlets of rating 32 A or less, unless an exception is permitted (411.3.3) • for the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3) • for cables concealed in walls at a depth not exceeding 50 mm (522.6.202; 522.6.203) • for cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203) • final circuits supplying luminaires within domestic (household) premises (411.3.4)	✓ ✓ ✓ ✓ ✓ ✓ ✓
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
5.14	Band II cables segregated / separated from Band I cables (528.1)	✓
5.15	Cables segregated / separated from communications cabling (528.2)	✓
5.16	Cables segregated / separated from non-electrical services (528.3)	✓
	Intentionally left blank	

Item No.	Description	Outcome
5.17	Termination of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526) • Connections soundly made and under no undue strain (526.6) • No basic insulation of a conductor visible outside enclosure (526.8) • Connections of live conductors adequately enclosed (526.5) • Adequately connected at point of entry to enclosure (glands, bushes etc. (522.8.5)	✓ ✓ ✓ ✓
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2(v))	✓
5.19	Suitability of accessories for external influences (512.2)	✓
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)	✓
5.21	Single pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.0	LOCATIONS CONTAINING A BATH OR SHOWER	
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	N/A
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	N/A
6.3	Shaver supply units complying with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	N/A
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671: 2018+A2 (701.415.2)	✓
6.5	Low voltage (e.g. 230 V) socket-outlets sited at least 2.5 m from zone 1 (701.512.3)	✓
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	✓
6.7	Suitability of accessories and controlgear etc for a particular zone (701.512.3)	✓
6.8	Suitability of current-using equipment for particular position within the location (701.55)	✓
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	
7.1	List all other specialist installations or locations present, if any. (Record separately the results of particular inspections applied)	N/A
8.0	PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S)	
8.1	Where the installation includes additional requirements and recommendations relating to Chapter 82, additional inspection items should be added to the checklist.	N/A

Inspected by

Name (Capital(s):

Howard Rose

Signature:

Howard Rose

Date:

16-11-23