



SALES INVOICE

Unit HM25, Holmfield Mills, Holmfield,
Halifax. West Yorkshire. HX3 6SN.

Tel: 01422 240782 Fax: 01422 240690
www.lepolfire.co.uk lepol@hotmail.co.uk
VAT Number: 945991567
Company Reg Number: 6799543

Invoice Address Heath U R C (Church) 11 Free School Lane Halifax HX3 0DW	Site Address 11 Free School Lane Halifax HX3 0DW	Invoice: 11995 Date: 09-02-2023 Order No: Contract Acc Ref: HEATHURC
---	---	---

Qty	Part No	Description	Each	Total
Work carried out as detailed on form no 010912				
20	RMC	Rental Maintenance	15.00	300.00
3	SUFA3	Supply 3 Litre Foam Extinguisher (INC)		
3	SUP2	Supply 2kg Dry Powder Extinguisher (INC)		
20	SS	Safety Seals (INC)		
6	SHO	Swivel Horn O - Ring (INC)		
6	ER	Extinguishers Removed For Safe Disposal (INC)		
1	SCPR	Schedule Program	1.95	1.95
1	FWB	Foam Wall Brackets	2.15	2.15
1	PS	Picto Signs	3.35	3.35
1		MCP Cover	7.95	7.95
1	FC	Appliance Fitting Charge	5.00	5.00
1	MH	0.75 Man Hours	26.25	26.25
1	AFAS	Annual Fire Alarm Service to BS 5839	130.00	130.00
1	AELS	Annual E/Lighting Test Activation to BS 5266	50.00	50.00
1		1 x failed bulkhead replaced	48.50	48.50
1		Electrical - minor remedials as time		

Please ask for full details of our terms and conditions. All goods remain the property of Lepol F&S until paid for in full. Invoices payable within 30 days unless a written agreement is in place.

MAKE CHEQUES PAYABLE TO: LEPOL FIRE & SECURITY LTD
BACS PAYMENTS: HSBC, 7 Commercial Street, Halifax. HX1 1HN.
Account: 92043793 Sort code: 40-23-05

Net Amount	575.15
VAT @ 20.00%	115.03
Amount Due	690.18

CONTRACT / AGREEMENT
INSPECTION REPORT
EQUIPMENT ORDER FORM

Email: lepol@hotmail.co.uk

VAT No. 945991567

Company Reg. 6799543



Unit HM25,
Holmfield Mills, Holmfield,
Halifax. HX3 6SN.

Tel: 01422 240782

Fax: 01422 240690

Customer Name:

Heath URC (Church)

Address:

11 Free School Lane,
Halifax. HX3 0DW

Invoice Address:

(if different)

email - Gill

Form No. 010912

Date:

9-2-2023

Order No:

Contract

Next service

due by end of:

Feb 2024

Code	Description	Test/ Serviced	G/T	R/C	Cartridge	Additive	Extended Service	U/S	S/E	New	Office
W9	9L. Water										
W6	6L. Water										
W3	3L. Water										
FA9	9L. AFF Foam										
FA6	6L. AFF Foam										
FA3	3L. AFF Foam	11	11					3		3	RM
FA2	2L. AFF Foam										
FB9	9L. Bio Foam										
FB6	6L. Bio Foam										
FB3	3L. Bio Foam										
FB2	2L. Bio Foam										
FP6	6L. Polar Foam										
WC6	6L. Wet Chemical										
WC3	3L. Wet Chemical										
WC2	2L. Wet Chemical										
MON9	9Kg Monnex										
P9	9Kg. ABC Powder										
P6	6Kg. ABC Powder										
P4	4Kg. ABC Powder										
P3	3Kg. ABC Powder										
P2	2Kg. ABC Powder	3						3		3	RM
P1	1Kg. ABC Powder										
CD5	5Kg. Carbon Dioxide										
CD2	2Kg. Carbon Dioxide	6									
F/A	Fire Alarm	1									
E/L	Emergency Lighting	1									
F/BL	Fire Blankets	2									
F/BU	Fire Buckets (sand)										
FRA	Fire Risk Assessment										
ELEC	Electrical Test	1									
		1 - Full annual Servicing to BS 5839									
		1 - Full test activation to BS 5839									
		1 - Minor remedials as time.									
Total Extinguishers		22									RM
Hose Reels											
General Comments											
1 x Failed Bulkhead replaced @ £48.50											

Code	Spare parts fitted	Qty	Office
HO	Headcap 'O' Ring		
DHF/W	Discharge Hose Foam/Water		
DHDP	Discharge Hose D/P		
D/N	Discharge Hose Nozzle		
DO	Discharge Hose 'O' Ring		
LH&H	Long Hose & Horn (CO ₂)		
SH	Swivel Horn (CO ₂) Frost Free Type		
S	Safety (pull tie) seals	20	RM
SP	Safety Pins		
SC	Safety Clips (O.K.)		
HRH	Hose Reel Hose 19mm		
HRN	Hose Reel Nozzle		
JC	Jubilee Clip		
WBC02	CO ₂ Wall Bracket		
WB	D/P & Water Wall Bracket	1	2-15
SHO	Swivel Horn 'O' ring	6	RM
HHW	5Kg CO ₂ Washer		
B	Extinguisher Bases		
	Antifreeze		
PLS	Photo-luminescent ID signs	1	3-35
C	Cabinets		
	Floor Stands	1	7-95
	Accepted by customer to have old appliances disposed of		
AFC	Appliance fitting charge	1	5-00
PC	Parking Charge		
	Callout		
	No Callout		
Time Taken	0.75	Mileage - Miles	
			26-25
Certificate awarded Non Compliance			
Staff instruction in use of extinguishers			
Information Sheet	✓	To arrange	
Verbal		Completed	
Rental maintenance contract/job	Yes	✓	No
THE CONTRACT - TO "OPT OUT" TICK HERE <input type="checkbox"/>			

Any Dry Powder extinguisher within your premises may cause significant mess, cloud vision and affect breathing when used.

LEG Test/Serviced - appliance/unit/system tested/serviced
G/T - gauge tested (stored pressure appliances only)
Extended Service - appliance has a discharge test
Additive - used additive
R/C - recharged/refilled
New - new appliance installed
S/E - appliance has been upgraded (new or refurbished)
U/S - appliance un-servicable (requires replacing)
Cartridge - new internal cartridge fitted

We (Lepol Fire) hereby certify that all the fire fighting provision and or system/s identifies on this inspection report/job order sheet have been serviced/tested/activated/installed in accordance and or in-line with the British Standards (BS 5306, 5839 and 5266 where applicable). It is a requirement that the end user carries out a monthly (minimum) visual check of all the fire fighting provision and regarding to the fire alarm/emergency lighting system/s, it is expected that a visual check along with a minor recorded test be carried out by a competent person, whereon all checks and or minor tests are fully logged. (any known defects must be logged, reported and acted on immediately), Nominated FireWardens/ Marshall's should carry out a logged visual check daily as part of their further responsibilities.

* Terms & Conditions on the reverse. *

Inspectors Name: P. JAYLOR. Inspectors Signature: [Signature] Eng. No: 240268.
Customer Name: Jane Customer Signature: [Signature] Position: [Signature]





Unit HM25, Holmfield Mills,
Holmfield, Halifax. West Yorkshire.
HX3 6SN.

Tel: 01422 240782 Fax: 01422 240690
www.lepolfire.co.uk lepol@hotmail.co.uk
VAT Number: 945991567
Company Reg: 6799543

Heath U R C (Church)
11 Free School Lane
Halifax
HX3 0DW

Heath U R C (Church)
11 Free School Lane
Halifax
HX3 0DW

CERTIFICATE OF MAINTENANCE

HEATHURC

09-02-2023

Paul Taylor (Junior)

This certificate certifies that we have inspected and serviced the equipment listed above in accordance with BS5306 2000 part 1 (hose reels) and part 3 (extinguishers). The certificate is valid up to the end of the month, 12 months from the date shown above.

Our engineer (stated on the certificate) believes that the cover provided meets the standard we recommend.

- 6 X 2kg Carbon Dioxide Ext. S/P (Basic Service)
- 8 X 3L A.F.F. Foam Ext. S/P (Basic Service)
- 3 X 2kg ABC Dry Powder S/P ext. (New-)
- 1 X 6' x 4' Fire Blanket (Basic Service)
- 3 X 3L A.F.F. Foam Ext. S/P (New-)
- 1 X 4' x 4' Fire Blanket (Basic Service)

Signed:



Service Worksheet

Customer: Heath U R C (Church)



Contract Ref: HEATHURC

SERVICE ADDRESS

Heath U R C (Church)
11 Free School Lane
Halifax
HX3 0DW

Last Service **09-FEB-2023**
31-JAN-2022
18-JAN-2021
26-SEP-2019
18-SEP-2018

Contact **Gill / Jane**
Tel No
Payment **15.00 / 1 / 15.00**

Date Started

Date Finished

Engineer
Paul Taylor (Junior)

No	Type	Wt Kg	Location	Age	TDR	Comment
1	3L-AFFF		ENTRANCE	2021	2026	
2	2KG-CO2		ENTRANCE	2018	2028	
3	3L-AFFF		LOUNGE	2021	2026	
4	2KG-ABC		CELLAR	2023	2028	
5	2KG-ABC		KITCHEN	2023	2028	
6	6X4-FB		KITCHEN	2018		
7	3L-AFFF		HALL	2021	2026	
8	2KG-CO2		HALL	2018	2028	
9	2KG-ABC		SMALL BOILER ROOM	2023	2028	
10	3L-AFFF		REAR HALL FIRE EXIT 1	2022	2027	
11	3L-AFFF		REAR HALL FIRE EXIT 2	2022	2027	
12	3L-AFFF		1ST FLOOR FIRE EXIT 1	2023	2028	
13	2KG-CO2		1ST FLOOR FIRE EXIT 1	2018	2028	
14	3L-AFFF		1ST FLOOR DISABLED EXIT	2023	2028	
15	2KG-CO2		SANCTUARY	2018	2028	
16	3L-AFFF		SANCTUARY	2023	2028	Fitted + Sign + Bracket
17	3L-AFFF		KITCHENETTE CORRIDOR	2019	2024	
18	2KG-CO2		KICHENETTE CORRIDOR	2018	2028	
19	4X4-FB		KITCHENETTE			
20	3L-AFFF		2ND FLOOR (LHS)	2019	2024	
21	2KG-CO2		2ND FLOOR (LHS)	2018	2028	
22	3L-AFFF		2ND FLOOR (RHS)	2019	2024	

Notes

Engineer's Notes

Engineer's report must be completed in full. All non-conforming equipment must be noted.

Engineer's signature.....

Customer's Signature.....



Unit HM25
Holmfield Mills
Holmfield
Halifax HX3 6SN



SERVICE CERTIFICATE FIRE ALARMS / EMERGENCY LIGHTING

SERVICE ADDRESS

Heath U R C (Church)
Free School Lane
Halifax
HX3 0DW

Contact

Gill / Jane

INVOICE ADDRESS

Heath U R C (Church)
Free School Lane
Halifax
HX3 0DW

Contact Tel No:

Quantity	Inventory	Recommendation / Report
1	Fire Alarm Panel	
1	Battery Charger	
2	Batteries	
✓	Call Points	Pass.
✓	Smoke Detectors	
✓	Heat Detectors	
✓	Sounders	
✓	Emergency Lights	Pass.

Spares	Qty		Qty		Qty
Call Point Glass		Rate of Rise Detector		Lamp	
Surface Call Point		Bell		Fuses	
Flush Call Point		Siren			
Ionization Detector		Batteries			
Optical Detector		Emergency Light			

The above system has been serviced to British Standards 5839 / 5266 Part 1 1988



Engineer Name P. Taylor

Customer Name

Engineer Signature P. Taylor

Customer Signature

Date 09-02-2023

Date