




HeatingGlobal LTD

anne-marie@heatingglobal.com

GAS CERTIFICATE

307440

HEATINGGLOBAL LTD, 19 SHERWOOD DRIVE,
PENDLEBURY, SWINTON, MANCHESTER, M27 4FZ
0161 211 6955



JOB ADDRESS <i>Heath URC, Free School</i>	INVOICE ADDRESS	SOUNDNESS TEST	PASS <i>Pass</i>	FAIL
<i>Laec. Halifax, HX3 0DN</i>		MBAR TEST PRESSURE <i>2mbars</i>	GAUGE PRESSURE <i>ligi</i>	
	<i>andyandgillbrooke@gmail.com</i>	LET BY TEST PERIOD <i>1min</i>	ECV ACCESSIBLE <i>yes</i>	
NAME <i>Jude</i>	NAME	STABILISATION TEST PERIOD <i>1min</i>	EARTH BONDING <i>yes</i>	
TEL <i>07812 720 833</i>	TEL	SOUNDNESS TEST PERIOD <i>2min</i>	PIPEWORK INSPECTION <i>ok</i>	
EMAIL <i>heathchurchhalifax@gmail.com</i>	EMAIL <i>gmail.com</i>	OK PRESSURE DROP <i>0mbars</i>	METER LOCATION <i>basement</i>	

LOCATION	MODEL	FLUE TYPE	PRESSURE / kW	SPLUDGE TEST	FLUE GAS	VENTILATION	HEAT EXCHANGER	PRV / VESSEL	SERVICED	SAFE TO USE
1 Basement	Britany II 97444732.04	B/F	21kw	Pass	0.0006	ok	ok	N/A	yes	yes
2 Lounge	Art 10-02-4310619281992	B/F	13.1kw	Pass	0.0004	ok	ok	N/A	yes	yes
3 Lounge	Art 10-02-43106192611995	B/F	13kw	Pass	0.0006	ok	ok	N/A	yes	yes
4 Boiler room	Ideal logic heat 30 21086300001936166	F/F	30kw	Fail	-	ok	ok	ok	yes	yes
5 Kitchen	Belling cooker 70733785	F/L	14.5kw	Pass	0.0002	ok	N/A	N/A	yes	yes
6 Office	Baxi Brazillia 9911128AF	B/F	3.6kw	Pass	0.0003	ok	ok	N/A	yes	yes
7 Hall	Art 10-02-4310619237179	B/F	13kw	Pass	0.0006	ok	ok	N/A	yes	yes
8 Hall	Art 10-02-4310618237181	B/F	13.1kw	Pass	0.0004	ok	ok	N/A	yes	yes
9 Hall	Art 10-02-4310619091044	B/F	13kw	Pass	0.0003	ok	ok	N/A	yes	yes
10 Church	Art 6-01-4310019059003	B/F	7.1kw	Pass	0.0004	ok	ok	N/A	yes	yes
11 Church	Art 6-01-4310019059004	B/F	7kw	Pass	0.0006	ok	ok	N/A	yes	yes
12 Church	Art 6-01-4310019059006	B/F	7.1kw	Pass	0.0003	ok	ok	N/A	yes	yes
13 Church	Art 6-01-4310019059001	B/F	7kw	Pass	0.0006	ok	ok	N/A	yes	yes
14 Church	Art 6-01-4310019059005	B/F	7.1kw	Pass	0.0005	ok	ok	N/A	yes	yes
15 Vestibule	Art 6-01-4310019059002	B/F	7kw	Pass	0.0004	ok	ok	N/A	yes	yes
16 * Parks road	Fan 135569 - flue manifold	Seals,	Flue elbow with	best paint	G.C. 41-	750-	22			
17										

CUSTOMER SIGNATURE	ENGINEER SIGNATURE	DATE
	<i>[Signature]</i>	<i>15/09/25</i>